



3 Garden Street  
Morwell Vic 3840  
[australiansolidfueltesting@gmail.com](mailto:australiansolidfueltesting@gmail.com)  
NATA Accreditation No. 20042

11 May 2022

Mr Greg Parker-Hill  
Pivot Stove & Heating Co.  
120 Victoria Street  
North Geelong Vic

To Whom it May Concern,

RE: BAL Rating for Room Seal Flue Kit

The Room Seal Kit has been tested to and passed both Appendix B and Appendix F of AS/NZS2918;2018. During this testing the flue kit is exposed to temperatures of greater than 1100°C for periods longer than 2hrs with no adverse effect on the integrity of the flue kit.

The Room Seal Flue kit is a fully sealed flue kit with no venting at the cowl or at the heating appliance. Therefore, there is no opening for bushfire sparks or embers to enter the dwelling via the cowl or outer casing as per a standard flue system. The flue kit is also constructed entirely of non-combustible materials.

It is in our opinion that the Room Seal Flue kit meets the requirements of BAL-40 and BAL-FZ building requirements.

Warm regards,

A handwritten signature in blue ink, appearing to read 'Steve Marland', is written over a light blue circular stamp.

Steve Marland  
Managing Director  
Australian Solid Fuel Testing